

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1517:112 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Commercial Products Group, 1130 Milepost Dr., Columbus, OH 43228
Contact: Andrew Keller (309) 762-0731

DESIGN: Models V1971 Series ZA1(15/75cd), V1971 Series KA1 (30/75cd), V1971 Series UA1 (75cd) and V1971 Series NA1 (110cd) strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/strobe rating, and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used in conjunction with separately listed compatible audible devices and fire alarm control units. For wall mounting and indoor use only.

XLf: 7125-0553:106

12-16-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager